

Comparison of RCC-MRx and ASME Subsection NH as Elevated Temperature Design Codes

25. Nov. 2015

Hyeong-Yeon Lee



Korea Atomic Energy Research Institute



I. Introduction

II. Elevated Temperature Design (ETD) Rules

III. Comparison of ETD codes


- Material properties**
- Design evaluation procedures**

IV. Application of the ETD rules to sodium test facilities

V. Design evaluation program, HITEP_RCC-MRx

VI. NRC Licensing concerns on ETD rules

VII. Summary



Introduction





I.1 Gen.IV Reactors & Design Rules (1/2)

❖ Generation IV Reactors under development in EU

- ASTRID (SFR)
- MYRRHA, ALFRED (LFR)
- ALLEGRO (GFR)

❖ ETD* rule for the Gen IV reactors (EU) and ITER

- **RCC-MRx**



Roadmap of Gen IV reactors in EU

I.1 Gen.IV Reactors & Design Rules (2/2)


❖ Gen IV roadmap* of Korea

- PGSFR** (SFR, prototype construction by 2028)
- NHDD*** (VHTR, demonstration plant by 2026)

❖ ETD rules for component design (Korea)

- (ASME Subsection NH+Div.5) & RCC-MRx (for design)
- RCC-MRx A16 (main for defect assessment including LBB)


❖ Application of ETD rules to sodium components in STELLA-1, STELLA-2 & SELFA test loop, and comparison of the design rules.




PGSFR

- 150MWe
- 545°C, ~1 bar(Pool type)
- RV : 8.7m (OD), 15.4m (H)

(*) Atomic Energy Committee of Korean Government approved in Dec. 2008
 (**) PGSFR : Prototype Gen IV Sodium-cooled Fast Reactor
 (***) NHDD : Nuclear Hydrogen Development and Demonstration




STELLA-1 Sodium test loop



STELLA-2 Sodium test loop

I.2 Two major materials in PGSFR*





II

ETD Rules



- **RCC-MRx**
- **ASME Section III Div.1 Subsection NH**
Section III Div.5

II.1 Elevated Temperature Design Codes



- **RCC-MRx** (2012 Ed. Dec. 2013 Addendum)
- **ASME Section III Subsection NH** (2015 Ed.) ⇒ merge to Div.5 (2017)
- **ASME Section III Div. 5** (High Temp. Reactors, 2015Ed.)
 - From 2017Ed. ASME Div.5 only to exist & ASME-NH to disappear.
- **ASME Draft Code Case for Alloy 617 (VHTR, 1989), to be Code Case in 2017**
- **JSME D&C code for Fast Reactors (JSFR), BDS(Monju) (SFR, Japan)**
- **KEPIC MNH (SFR, Korea)**

II.2 ASME Section III Div.5 - contents

Subsection HA — General Requirements

- Subpart A — Metallic Materials
- Subpart B — Graphite Materials
- Subpart C — Composite Materials

Subsection HB — Class A Metallic Pressure Boundary Components

- Subpart A — Low Temperature Service
- Subpart B — Elevated Temperature Service ← N-499-1 : HBB
ASME-NH : to be merged in HBB (^17)

Subsection HC — Class B Metallic Pressure Boundary Components

- Subpart A — Low Temperature Service
- Subpart B — Elevated Temperature Service ← CC-N253

Subsection HF — Class A and B Metallic Supports

- Subpart A — Low Temperature Service

Subsection HG — Class A Metallic Core Support Structures

- Subpart A — Low Temperature Service
- Subpart B — Elevated Temperature Service

Subsection HH — Class A Nonmetallic Core Support Structures

- Subpart A — Graphite Materials
- Subpart B — Composite Materials

- ❖ **Code Case N-499 ⇒ Div. 5 HBB**
(Use of SA-533 & SA-508 for Limited Elevated Temp Service)
- ❖ **Code Case N-253 ⇒ Div. 5 HCB**
(Construction of Class 2 or 3 Components)

Div.1 Class 1 & CS ⇒ Div. 5 Class A
Div.1 Class 2 ⇒ Div. 5 Class B
Div.1 Class 3 & MC ⇒ N/A To Div. 5

❖ Section III Div.1

SECTIONS

- I Rules for Construction of Power Boilers
- II Materials
 - Part A — Ferrous Material Specifications
 - Part B — Nonferrous Material Specifications
 - Part C — Specifications for Welding Rods, Electrodes, and Filler Metals
 - Part D — Properties (Customary)
 - Part D — Properties (Metric)
- III Rules for Construction of Nuclear Facility Components
 - Subsection NCA — General Requirements for Division 1 and Division 2
 - Appendices
 - Division 1
 - Subsection NB — Class 1 Components
 - Subsection NC — Class 2 Components
 - Subsection ND — Class 3 Components
 - Subsection NE — Class MC Components
 - Subsection NF — Supports
 - Subsection NG — Core Support Structures
 - Subsection NH — Class 1 Components in Elevated Temperature Service
 - Division 2 — Code for Concrete Containments
 - Division 3 — Containments for Transportation and Storage of Spent Nuclear Fuel Material and Waste
 - Division 5 — High Temperature Reactors

II.3 RCC-MRx Procedures : strains

□ Total strain

- determined from total stress range (peak included)

$$\Delta \bar{\sigma}_{tot} = \Delta(\bar{P} + \bar{Q} + \bar{F})$$



$$\Delta \bar{\epsilon}_{el+pl} = \Delta \bar{\epsilon}_1 + \Delta \bar{\epsilon}_2 + \Delta \bar{\epsilon}_3 + \Delta \bar{\epsilon}_4$$

➤ Total strain



$$\Delta \bar{\epsilon} = \Delta \bar{\epsilon}_{el+pl} + \Delta \bar{\epsilon}_{cr}$$

$$\Delta \bar{\epsilon}_1 + \Delta \bar{\epsilon}_2 + \Delta \bar{\epsilon}_3 = K_\epsilon \Delta \bar{\epsilon}_{fic} + \Delta \bar{\epsilon}_i$$

$$\Delta \bar{\epsilon}_{fic} = \sqrt{\frac{2}{3} \frac{1+\nu}{E} \left(\Delta \bar{\sigma}_{tot} - \frac{3E}{2(1+\nu)} \cdot \Delta \bar{\epsilon}_i \right) \cdot (\Delta \bar{\epsilon}_1 + \Delta \bar{\epsilon}_2 - \Delta \bar{\epsilon}_i)}$$



$$\bar{\Delta\epsilon}_1 = \frac{2}{3} (1+\nu) \frac{\bar{\Delta\sigma}_{tot}}{E}$$




$$\bar{\Delta\epsilon}_4 = (K_\nu - 1) \bar{\Delta\epsilon}_1$$

II.4 RCC-MRx Procedures : C-F Damage

$$\bar{\sigma}_k = \text{Mean } \bar{P} + K_s \Delta \bar{\sigma}^*$$

$$\bar{\sigma}_k = \text{Mean } \bar{P} + K_s \sigma_r$$

Figure RB 3262.123c: determination of σ_k from s_r and \bar{P}_{\max}




➤ Fatigue damage

$$V(\bar{\Delta \epsilon}) = \sum \frac{n_i}{N_{ai}}$$

➤ Creep damage

$$W(\sigma) = \sum \left(\frac{\sigma_k}{0.9}; \theta \right)$$




II.5 ASME-NH Overall Procedures



Materials

- 304SS
- 316SS
- 2.25Cr-1Mo
- Mod.9Cr-1Mo
- Alloy 800H
- Alloy 718



II.6 Isochronous Curve in ASME-NH



- Used extensively in ASME-NH for the determination of ;
- + strain range,
- + fatigue damage & creep damage
- Based on uniaxial, monotonic data : very conservative

T-1800





FIG. T-1800-B-5 AVERAGE ISOCHRONOUS STRESS-STRAIN CURVES

Isochronous Curve 316SS - 540°C



III

Comparison of ETD* Codes



- **Material Properties (chem. Composition incl.)**
- **Design evaluation procedures**

III.1 Chemical compositions (316 & Gr.91)

❖ 316 Stainless steel

Code/Test	Grade	C	Mn	P	S	Si	Cr	Ni	Mo	N	B	other
ASME	316SS (Sec.III - NH)	0.04-0.06	1.0-2.0	<0.03	<0.02	0.6	17.0-18.0	11.0-12.5	2.5-3.0	0.04-0.07	0.003	Al 0.05
	316SS (Sec.II-part A)	0.08	2.0	0.045	0.03	1.0	16.0-18.0	10.0-14.0	2.0-3.0	
	316H (Sec.II-part A)	0.04-0.10	2.0	0.045	0.03	1.0	16.0-18.0	10.0-14.0	2.0-3.0	
	316LN (Sec.II-part A)	0.03	2.0	0.045	0.03	0.75	16.0-18.0	10.0-14.0	2.0-3.0	0.10-0.16	...	
	316L (Sec.II-part A)	0.03	2.0	0.045	0.03	0.75	16.0-18.0	10.0-14.0	2.0-3.0	0.1	...	
RCC-MRx	316LN	0.03	1.6-2.0	0.03	0.015	0.5	17.0-18.0	12.0-12.5	2.3-2.7	0.06-0.08	...	
	316L	0.03	2.0	0.03	0.015	1.0	16.5-18.5	10.5-13.0	2.5-3.0	≤0.11	...	

❖ Grade 91


Code/Test	Grade	C	Mn	P	S	Si	Cr	Ni	Mo	N	Nb	other
ASME	Gr.91	0.06-0.15	0.25-0.66	0.025	0.012	0.18-0.56	7.90-9.60	0.43	0.80-1.10	0.025-0.080	...	Al. 0.02
RCC-MRx	X10CrMoVN b9-1 (Gr.91)	0.080-0.120	0.30-0.60	≤0.020	≤0.005	0.20-0.50	8.00-9.50	≤0.20	0.85-1.05	0.03-0.07	0.06-0.10	Al. ≤0.040

III.2 Comparison of Properties : Y_S , T_S , S_m


□ Yield strength, Tensile strength & Design stress intensity of Gr.91 steel

➤ RCC-MRx properties are more conservative.



Y_S (Gr.91)



T_S (Gr.91)




❖ Design stress intensity, S_m of Gr.91




III.3 Comparison of Properties : Fatigue

- Fatigue strength data : RCC-MRx properties are higher for 316LN ($N > 200$), lower for Gr.91 steel. (than ASME-NH)



Fatigue strength (316 @ 550°C)



Fatigue strength (Gr.91)


(RCC-MRx @ 550°C, ASME-NH @ 540°C)

III.3 Comparison of Properties : Creep


□ Creep rupture strength : RCC-MRx(316L,316LN) values are higher for 316 (CRS > 270MPa), and lower for Gr.91 steel (than ASME-NH).

❖ ASME-NH : Creep data of 500,000h provided for Alloy 800H (from 2013Ed.)

“Creep data of 500,000h to be provided for 316SS, P91, P22, 304SS from 2017Ed.*”



Creep rupture strength (316 @550°C)



Creep rupture strength (Gr.91 @550°C)


III.4 Thermal Aging in RCC-MRx



❖ **316L(N)** : TA considered in J-R curve


❖ **Gr.91** : TA Not considered in TS, YS & S_m

A9.J1S.812c: J-R curves at 550°C



	500 °C	525 °C	550 °C	600 °C	650 °C
moderate thermal ageing	175 000 h	64 000 h	25 000h	4 000 h	950 h
advanced ageing		280 000 h	110 000 h	19 000 h	4 000 h

Figure A3.18AS.41: values of $R'_{p0.2}$, R_m , S_m and S - RM 242-2 and RM 243-1 X10CrMoVNb9-1



A3.1S.51 THERMAL AGEING COEFFICIENT (NOT SUPPLIED)

(In case of 316LN @600C : $F_v(T_m) = 30,000$ hrs.)

RCC-MRx (2013 Adm.)

III.5 Thermal Aging in ASME-NH



Table NH-3225-2

Tensile and Yield Strength Reduction Factor Due to Long Time Prior Elevated Temperature Service

Material	Service Temp., °F (°C)	YS Reduction Factor	TS Reduction Factor
304SS	≥ 900 (480)	1.00	0.80
316SS	≥ 900 (480)	1.00	0.80
800H	≥ 1,350 (730)	0.90	0.90
2 ¹ / ₄ Cr-1Mo	≥ 800 (425)	[Note (1)]	[Note (1)]
9Cr-1Mo-V	≥ 900 (480)	1.0	[Note (2)]



GENERAL NOTE: No reduction factor required for service below the indicated temperature.

NOTES:

- (1) See Tables NH-3225-3A and NH-3225-3B are selected to correspond to the maximum wall-averaged temperature achieved during any Levels A, B, or C Service Loading.
- (2) See Table NH-3225-4.

- Started consideration of TA effect from 2013 Ed.
- **“No ‘long-time service effect @ET*’ on YS for Gr.91 & 316SS (T ≥ 480°C)”**
- **“It may be necessary to adjust S_m** values (NH-3221)”**
- **Validation of the Table NH-3225-2 may be necessary (study underway @KAERI)**

(*) Elevated Temperature

(**) Design Stress Intensity (lesser of (1/3 UTS, 2/3 YS))

III.6 Comparison of Design Rules



	RCC-MRx	ASME-NH
<ul style="list-style-type: none"> □ Calculation of total strain range and creep damage 	Creep laws directly used.	Isochronous curves used.
Elastic Follow-up	Explicitly considered (q=3, default)	Implicitly considered
<ul style="list-style-type: none"> □ Strain limits 	1% (membrane), 2%(bending)	1% (membrane), 2%(bending), 5%(peak)
Peak terms in strain calculation	Contained in total S.I (convenient)	Should be decomposed in elastic approach
<ul style="list-style-type: none"> □ Ratcheting rule 	Efficiency diagram method (Gr.91 pending)	Mod. Bree diagram (O'Donnell Porowski)
<ul style="list-style-type: none"> □ Environmental effects 	Explicitly to be considered (irradiation, thermal ageing etc.) (@ beginning stage)	No guideline (except thermal aging, designer's duty)

□ RCC-MRx provides (that ASME-NH does not provide)

- Guide for LBB and defect assessment (A16)
- Heat Exchangers (RB-3900)
- Box Structure (RB-3800) etc.

III.7 C-F Damage for Weldment

❖ ASME-NH

$$\sum_{j=1}^p \left(\frac{n}{N_d} \right)_j + \sum_{k=1}^q \left(\frac{\Delta t}{T_d} \right)_k \leq D$$


❖ RCC-MRx

1. Fatigue Damage

$$N_d(\text{HAZ})^{(*)} = \frac{1}{2} N_d(\text{base})$$

2. Creep Damage

T_d determined from $S_r \times R$ (Weld SRF)



1. Fatigue Damage

$$\overline{\Delta \sigma}_{weld} = \text{FSRF} \times \overline{\Delta \sigma}_{base}$$

$$\varepsilon_t(\text{HAZ}) = J_f * \varepsilon_{t0}(\text{base})$$

2. Creep Damage

T_d determined from $S_r \times J_r$




FIG. I-14.6F 9Cr-1Mo-V – EXPECTED MINIMUM STRESS-TO-RUPTURE, ksi (MPa)

III.8 C-F* Damage Envelope

❖ Linear Damage Summation Rule (LDSR)

- Severud (1970s)
- Based on **cavity growth** of Austenitic S.S at tensile hold

$$\sum_{j=1}^P \left(\frac{n}{N_d} \right)_j + \sum_{k=1}^q \left(\frac{\Delta t}{T_d} \right)_k \leq D$$






Fig. 11. Scanning electron micrograph of microcrack and creep damage around a main crack under creep condition (SUS 304 stainless steel, 650°C, $\sigma_c = 191$ MPa).

❖ ASME-NH



❖ RCC-MRx




C-F crack Growth (304SS, 650°C)


III.9 Code Case N-812 ; Gr.91 Alternative C-F Rule

❖ Procedures of CC N-812 applicable (Gr.91)

- Elastic Analysis of ASME-NH (T-1430)
- Isochronous Curves (T-1433(a) Step 5(2))



ASME-NH




Code Case N-812

(Alternative C-F Damage Envelope for
9Cr-1Mo-V for use with T-1433(a) Step 5(2))




IV

Application of the ETD rules to sodium test facilities



STELLA-1




STELLA-2


❖ STELLA : Sodium integral effect Test Loop for safety simulation and Assessment

❖ SELFA : Sodium thermal-hydraulic Experiment Loop for Finned-tube sodium-to-Air heat exchanger


IV.1 Main components in STELLA-1 & 2




DHX



AHX



Loop heater vessel



Reactor Vessel (ST-2)




Expansion tank



STELLA-1 test facility


IV.2 FE Model & thermal load condition

- 3D CAD Model based FE Model. (ABAQUS)
- 225,511 3D Brick Elements
- 290,790 nodes




Schematic and 3D FE Model of DHX

□ Primary side



□ Secondary side




- No. of cycles = 500.
- Hold Time / C-F cycle = 30 hr

IV.3 Heat Transfer Analysis




❖ Temperature Contour of Step 4 (410 → 510 °C Transient)




IV.4 Stress Analysis : Primary Load

❖ Stress Contour of DHX



IV.5 Stress Analysis : Secondary Load



❖ Stress Contour of DHX (at the end of Heat Up)



IV.6 Creep-Fatigue Damage (DHX)

❖ DHX (Gr.91)


@ nozzle pt. 3



$$\sum_{j=1}^p \left(\frac{n}{N_d} \right)_j + \sum_{k=1}^q \left(\frac{\Delta t}{T_d} \right)_j \leq D$$


DHX (ASME-NH)

DHX (RCC-MRx)



❖ C-F damage @ nozzle pt.3




DHX	ASME-NH	RCC-MRx
D_f	0.00005	0.00005
D_c	0.02051	0.00023



❖ Conservatism (Gr.91) : RCC-MRx < ASME-NH

IV.7 FE Model & thermal load condition for AHX

- 3D CAD Model based FE Model. (ABAQUS)
- 523,752 3D Brick Elements
- 803,199 nodes




Sodium temp. at Inlet nozzle

AHX (sodium-to-air HX)

IV.8 Heat Transfer Analysis





❖ Temperature Contour of Step 4 (400 → 500 °C Transient (Heat Up End))




IV.9 Stress Analysis : Secondary Load

❖ Stress Contour of AHX (at the end of Heat Up)


S, Mises
(Avg: 75%)




T1 Nozzle




S, Mises
(Avg: 75%)



Tube Sheet




S, Mises
(Avg: 75%)




IV.10 Creep-Fatigue Damage (AHX)

❖ AHX (316L)



❖ C-F damage @ T1 Nozzle







AHX	ASME-NH	RCC-MRx
D_f	0.16706	0.00540
D_c	0.00023	0.00010

❖ Conservatism (Gr.91) : RCC-MRx < ASME-NH

IV.11 Temperature Analysis : STELLA-2


❖ Distribution of temperature




Temp. distribution @4.25h after Heat-up started

IV.12 Stress Analysis & C-F Damage (STELLA-2)


❖ Stress distributions under thermal loads



Stress intensities after Heat-up (4.25h)



❖ C-F damage @ Redan corner



Redan	ASME-NH	RCC-MRx
D_f	0.05690	0.00017
D_c	0.00010	0.01020

❖ **Conservatism : RCC-MRx < ASME-NH for fatigue**
RCC-MRx > ASME-NH for creep




Design evaluation program, **HITEP_RCC-MRx**



V.1 Programming of RCC-MRx (1/3)

❖ Web-based calculation program of RCC-MRx (language : php)

- RB-3200 (Design by analysis) programming completed.
- FY2016 : RB-3600(DBR) to be programmed.




[HITEP_RCC-MRx program cover screen]

V.1 Programming of RCC-MRx (2/3)



- HITEP_RCC-MRx verification (1)
 - Load Controlled Limits(1) – Input window



Load Controlled Limits (2)

Material: 316LN

Service Level: Level A Level C Level D

UNIT: MPa Pa

[Primary Stress Component (Max)]

	σ_x	σ_y	σ_z	σ_{xy}	σ_{yz}	σ_{zx}
P_m (MPa)	0.01015	24.75	4.16	-0.1056	0	0
L_m (MPa)	0	0	0	0	0	0
P_b (MPa)	-0.02637	11.23	3.401	0	0	0
F (MPa)	-1.819E-18	0.02109	0.01483	0.02226	0	0

[Secondary Stress Component (Max)]

	σ_x	σ_y	σ_z	σ_{xy}	σ_{yz}	σ_{zx}
Q_m (MPa)	-0.1128	-0.000255	-10.83	3.658	0	0
Q_b (MPa)	0.2093	-140.9	-37.99	0	0	0
F (MPa)	0	0.7269	0.8799	0	0	0

[Secondary Stress Component (M

	σ_x	σ_y	σ_z
Q_m (MPa)	-0.1961	-0.000088	-77.25
Q_b (MPa)	0.1042	-173.1	-65.25
F (MPa)	4.366E-17	-1.359	-2.581

Max. temp (°C): 510 J-integral

[OK] | [Close]

Load Controlled Limits (2)

Load-Controlled Limits(2)(Level A)

Material: 316L

Evaluation Items	Calculated	Limit value	Remark
Max($P_L + P_b$) + ΔQ Max($P_L + P_b$) + $\Delta Q < 3S_m$	130.54 Mpa	292.8 Mpa	OK!!

[Back] | [Next]

[Load-Controlled Limits(2) evaluation m

V.1 Programming of RCC-MRx (3/3)



- HITEP_RCC-MRx verification

- Creep-Fatigue Damage - window

Creep-Fatigue Damage

Material: 316LN

Total Hold Time: 617 hour

Hold Temperature: 510 °C

Design Number of Cycles(n): 851

UNIT: MPa Pa

[Primary Stress Component (Max)]

	σ_x	σ_y	σ_z	σ_{xy}	σ_{yz}	σ_{zx}
P _m	0.01015	24.75	4.16	-0.1056	0	0
L _m	0	0	0	0	0	0
P _b	-0.02637	11.23	3.401	0	0	0
F	-1.819E-18	0.02109	0.01483	0.02226	0	0

[Primary Stress Component (Min)]

	σ_x	σ_y	σ_z	σ_{xy}	σ_{yz}	σ_{zx}
P _m	0	0	0	0	0	0
L _m	0	0	0	0	0	0
P _b	0	0	0	0	0	0
F	0	0	0	0	0	0

[Secondary Stress Component (Max)]

	σ_x	σ_y	σ_z	σ_{xy}	σ_{yz}	σ_{zx}
Q _m	-0.1128	-0.000255	-10.83	3.658	0	0
Q _b	0.2093	-140.9	-37.99	0	0	0
F	0	0.7269	0.8799	-0.7823	0	0

[Secondary Stress Component (Min)]

	σ_x	σ_y	σ_z	σ_{xy}	σ_{yz}	σ_{zx}
Q _m	-0.1961	-0.000088	-77.25	-2.266	0	0
Q _b	0.1042	-173.1	-65.25	0	0	0
F	4.366E-17	-1.359	-2.581	0.4839	0	0

[OK] [Close]

HITEP_RCC High Temperature des

KAERI

Load-Controlled Limits(1)

Load-Controlled Limits(2)

Inelastic Strain Limits

Creep-Fatigue Damage

Creep-Fatigue Damage

Creep-Fatigue Damage

Material



$$\sum_{j=1}^p \left(\frac{n}{N_d} \right)_j + \sum_{k=1}^q \left(\frac{\Delta t}{T_d} \right)_k \leq D$$

	Calculated	Limit value	Check
Fatigue damage	9.2199E-12		OK!!
Creep damage	0.0081		OK!!

[Back] [Next]


V.2 Verification of HITEP_RCC-MRx (1/2)

Verification of the program (STELLA-2)



Contents	Calculated	Limit value	Remark
Primary Stress Limit			
P_m	24.7 MPa	91.8 MPa	OK
P_L	24.7 Mpa	137.7 MPa	OK
$P_L + P_B$	33.6 MPa	137.7 MPa	OK
Creep-Fatigue Damage			
Fatigue Damage	0.000172	0.9996	OK
Creep Damage	0.01020	1	OK


[Summary of Results]



[Creep-fatigue damage evaluation]

V.3 Programming of HITEP_RCC-MRx (2/2)


Verification of the program (PGSFR)



[2D Axisymmetric FE model of Reactor Vessel]

Contents	Calculated	Limit value	Remark
Primary Stress Limit			
P_m	24.75 MPa	105.6 MPa	OK
$P_L + P_B$	24.51 MPa	159.7 MPa	OK
$P_L + P_B / K_t$	24.56 MPa	138.4 MPa	OK
Creep-Fatigue Damage			
Fatigue Damage	2.4E-04	0.2360	OK
Creep Damage	0.4492	1	OK

[Summary of Results]



[Creep-fatigue damage evaluation]

☐ List of Elevated Temperature Structural Integrity Issues (25 items) : 1983

1. **Transition joints**
2. **Weld residual stresses**
3. Design loading combinations
4. Creep-rupture and fatigue damage
5. Simplified bounds for creep ratcheting
6. Thermal striping
7. Creep-fatigue analysis of class 2 and 3 piping
8. Are limits of Case N-253 for elevated temperature class 2 and 3 components met?
9. Creep buckling under axial compression – design margins
10. Identify areas where Appendix T rules are not met
11. Rules for component supports at elevated temperature
12. Strain and deformation limits at elevated-temperature
13. **Evaluation of weldments**
14. Material acceptance criteria for elevated temperature
15. Creep-rupture damage due to forming and **welding**
16. Mass transfer effects
17. **Environmental effects**
18. Fracture toughness criteria
19. **Thermal aging effects**
20. **Irradiation effects**
21. Use of simplified bounding rules at discontinuities
22. Elastic follow-up
23. **Design criteria for elevated-temperature core support structures and welds**
24. Elevated-temperature data base for mechanical properties
25. **Basis for leak-before-break at elevated temperatures**

* : Regulatory Safety Issues on ASME-NH

Issues on

- **weldments** : 5EA
- Creep / fatigue : 5EA
- **Environ. effects** : 3EA
- LBB : 1EA
- Frac. Toughness: 1EA.

VII. Summary

- ❖ **Comparison of ETD rules, RCC-MRx & ASME-NH has been conducted and application of the rules to the STELLA-1&2 and SELFA was conducted.**
- ❖ **Full 3D FEA conducted for the components and C-F damage was evaluated according to RCC-MRx and ASME-NH for**
 - + **Heat Exchangers (DHX, AHX, FHX) & RI (Redan) : within C-F design limits**
 - ⇒ **Conservatism depends on the problems although generally it tends to be ;
RCC-MRx < ASME-NH.**
 - ⇒ **Conservatism of material properties depends although RCC-MRx properties
such as YS, Fatigue strength, creep rupture strength etc.)**
- ❖ **Computer program of HITEP_RCC-MRx for evaluation as per RCC-MRx has been developed.**
 - + **RB-3200 (DBA*) programming completed**
 - + **RB-3600 (DBR**) to be developed in FY2016.**



VI.1



Thank You!

Hyeong-Yeon Lee (KAERI)

hylee@kaeri.re.kr

